


LS2000 Heat Exchanger Wiring Diagram


TF-LS2000-03



FROM
CONTROLLER

FAN 1 (P2/3, 1-3)	TO NEW TAG FAN	
PIN 1 (BLACK)	RED	(RTN=0V) +
PIN 2 (RED)	BLACK	-48 VOLTS
PIN 3 (BLUE)	BLUE / WHITE	SENSOR
FAN 2 (P2/3, 4-6)	TO NEW TAG FAN	
PIN 4 (GREEN)	RED	(RTN=0V) +
PIN 5 (ORANGE)	BLACK	-48 VOLTS
PIN 6 (WHITE)	BLUE / WHITE	SENSOR

If fans don't run, press test button to activate thermostat
 If fans don't run after pressing test button, check thermostat



150 Cooper Rd. (F-15)
 W. Berlin, NJ 08091

www.tagcords.com

Telephone: (856) 753-8585
 Fax : (856) 768-7645

Telecom Assistance Group